



TECHNICAL BULLETIN

PERMIT AND RESOURCE MANAGEMENT DEPARTMENT

M-1X

2550 Ventura Avenue, Santa Rosa, CA 95403
(707) 565-1900 FAX (707) 565-1103

Fireplace Log Lighter Installation Restrictions

INTRODUCTION

A fireplace log ignition outlet is not considered an appliance, but as an accessory to a fireplace. As an unlisted appliance some restrictions apply to its use and location.


TECHNICAL DETAILS

Gas log lighters are prohibited in fireplaces located in any bedroom or room used for sleeping purposes.

Any Liquefied-Petroleum Gas fired log lighters are prohibited in multi-level rooms that create an area where unburned fuel or vapors may collect.

When installed in a premanufactured fireplace, the unit must be listed for its installation.

Log Lighter Installation



This installation not approved
for Liquefied Petroleum Gas

REFERENCES

1998 California Mechanical Code Sections 1312.14; 1314.1
1998 California Plumbing Code Sections 1211.14; 1213.5
Sonoma County Residential Construction Handbook Section 16

S:\PLAN_CHECK\Technical Bulletins X-Pre2008 WP\LOGLIGHTER_X.wpd
Effective Date: 9/01/01

Revised: 12/31/01